

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

Region/State	Name of Thermal Power Station		Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Actual Stock				Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock
							In '000 Tonnes'					
							Indigenous	Import	Total	In Days		
A	B	C	D	E	F	G	H	I	J=(I/F)			
Haryana												
1	INDIRA GANDHI STPP	JV	0.67	13.3	13.19	13.3	291.9	0.0	291.9	22		
2	MAHATMA GANDHI TPS	P	0.61	16.8	10.63	16.8	57.9	0.0	57.9	3		
3	PANIPAT TPS	S	0.71	7.2	6.68	7.2	109.6	0.0	109.6	15		
4	RAJIV GANDHI TPS	S	0.73	5.8	11.64	11.6	374.7	0.0	374.7	32		
5	YAMUNA NAGAR TPS	S	0.72	2.2	5.73	5.7	249.4	0.0	249.4	44		
Punjab												
6	GH TPS (LEH.MOH.)	S	0.68	1.6	8.28	8.3	234.7	0.0	234.7	28		
7	GOINDWAL SAHIB TPP	P	0.71	1.1	5.04	5.0	17.9	0.0	17.9	4		Materialization against the ACQ is more than trigger level
8	RAJPURA TPP	P	0.55	9.3	10.14	10.1	265.9	0.0	265.9	26		
9	ROPAR TPS	S	0.68	1.5	7.51	7.5	181.5	0.0	181.5	24		
10	TALWANDI SABO TPP	P	0.66	18.6	17.29	18.6	79.2	0.0	79.2	4		Materialization against the ACQ is more than trigger level
Rajasthan												
11	CHHABRA-I PH-1 TPP	S	0.50	6.6	3.31	6.6	1.6	0.0	1.6	0		Materialization against the ACQ is more than trigger level
12	KAWAI TPS	P	0.60	15.5	10.39	15.5	87.5	0.0	87.5	6		Materialization against the ACQ is more than trigger level
13	KOTA TPS	S	0.71	18.7	11.59	18.7	112.7	0.0	112.7	6		
14	SURATGARH TPS	S	0.49	8.7	9.67	9.7	48.6	0.0	48.6	5		Materialization against the ACQ is more than trigger level
Uttar Pradesh												
15	ANPARA C TPS	P	0.64	9.3	10.15	10.1	211.0	0.0	211.0	21		
16	ANPARA TPS	S	0.65	33.2	22.69	33.2	503.4	0.0	503.4	15		
17	BARKHERA TPS	P	0.80	0.0	0.95	1.0	7.8	0.0	7.8	8		Materialization against the ACQ is more than trigger level
18	DADRI (NCTPP)	C	0.67	8.8	16.20	16.2	384.9	16.0	400.8	25		
19	HARDUAGANJ TPS	S	0.74	0.0	5.92	5.9	198.6	0.0	198.6	34		
20	KHAMBARKHERA TPS	P	0.80	0.0	0.95	1.0	4.2	0.0	4.2	4		Materialization against the ACQ is more than trigger level
21	KUNDARKI TPS	P	0.76	0.0	0.90	0.9	14.2	0.0	14.2	16		
22	LALITPUR TPS	P	0.61	19.5	15.99	19.5	257.4	0.0	257.4	13		
23	MAQSODPUR TPS	P	0.79	0.0	0.94	0.9	14.0	0.0	14.0	15		
24	MEJA STPP	JV	0.67	11.0	11.76	11.8	357.2	0.0	357.2	30		
25	OBRA TPS	S	0.77	10.3	11.09	11.1	125.6	0.0	125.6	11		
26	PARICHHA TPS	S	0.71	11.1	10.72	11.1	253.0	0.0	253.0	23		
27	PRAYAGRAJ TPP	P	0.63	20.8	16.34	20.8	45.0	0.0	45.0	2		Materialization against the ACQ is more than trigger level
28	RIHAND STPS	C	0.64	35.0	25.28	35.0	428.6	0.0	428.6	12		
29	ROSA TPP Ph-I	P	0.66	6.2	10.39	10.4	263.8	0.0	263.8	25		
30	SINGRAULI STPS	C	0.66	28.8	17.45	28.8	407.2	0.0	407.2	14		
31	TANDA TPS	C	0.69	15.4	16.14	16.1	391.3	0.0	391.3	24		
32	UNCHAHAR TPS	C	0.67	17.9	13.65	17.9	196.9	0.0	196.9	11		
33	UTRAULA TPS	P	0.78	0.0	0.93	0.9	9.7	0.0	9.7	10		
Total of Northern Region											0	
Western												
Chhatisgarh												
34	AKALTARA TPS	P	0.64	18.2	15.25	18.2	83.1	0.0	83.1	5		Materialization against the ACQ is more than trigger level
35	BALCO TPS	P	0.71	8.9	5.60	8.9	59.1	18.1	77.2	9		
36	BANDAKHAR TPP	P	0.71	3.1	2.81	3.1	41.0	0.0	41.0	13		
37	BARADARHA TPS	P	0.77	19.8	12.25	19.8	188.6	0.0	188.6	10		
38	BHILAI TPS	JV	0.76	7.5	5.01	7.5	104.3	0.0	104.3	14		
39	BINJKOTE TPP	P	0.75	3.2	5.95	6.0	2.0	0.0	2.0	0		Materialization against the ACQ is more than trigger level
40	DSPM TPS	S	0.69	8.4	4.56	8.4	109.0	0.0	109.0	13		
41	KORBA STPS	C	0.67	38.7	22.94	38.7	247.6	0.0	247.6	6		
42	KORBA-WEST TPS	S	0.78	21.5	13.79	21.5	126.1	0.0	126.1	6		

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

Region/State	Name of Thermal Power Station		Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Actual Stock			In Days	Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock
							In '000 Tonnes'					
							Indigenous	Import	Total			
A	B	C	D	E	F	G	H	I	J=(I/F)			
43	LARA TPP	C	0.66	23.8	13.92	23.8	457.6	0.0	457.6	19		
44	NAWAPARA TPP	P	0.79	0.0	6.28	6.3	23.2	0.0	23.2	4		Materialization against the ACQ is more than trigger level
45	PATHADI TPP	P	0.65	8.8	5.18	8.8	102.5	0.0	102.5	12		
46	SIPAT STPS	C	0.68	35.4	26.62	35.4	498.7	0.0	498.7	14		
47	TAMNAR TPP	P	0.84	23.2	26.52	26.5	312.7	0.0	312.7	12		
48	UCHPINDA TPP	P	0.75	16.9	14.22	16.9	91.6	0.0	91.6	5		Materialization against the ACQ is more than trigger level
Gujarat												
49	GANDHI NAGAR TPS	S	0.69	5.8	5.71	5.8	73.0	0.0	73.0	13		
50	SABARMATI (D-F STATIONS)	P	0.57	3.2	2.74	3.2	58.9	92.5	151.4	47		
51	UKAI TPS	S	0.67	14.6	9.85	14.6	29.4	0.0	29.4	2		Materialization against the ACQ is more than trigger level
52	WANAKBORI TPS	S	0.67	27.9	20.22	27.9	88.9	0.0	88.9	3		Materialization against the ACQ is more than trigger level
Madhya Pradesh												
53	AMARKANTAK EXT TPS	S	0.65	3.2	1.80	3.2	26.9	0.0	26.9	8		
54	ANUPPUR TPP	P	0.65	18.6	10.31	18.6	178.0	0.0	178.0	10		
55	BINA TPS	P	0.74	4.3	4.88	4.9	17.8	0.0	17.8	4		Materialization against the ACQ is more than trigger level
56	GADARWARA TPP	C	0.66	9.3	13.93	13.9	315.1	56.1	371.3	27		
57	KHARGONE STPP	C	0.60	13.7	10.45	13.7	64.8	0.0	64.8	5		Materialization against the ACQ is more than trigger level
58	SANJAY GANDHI TPS	S	0.82	19.1	14.57	19.1	137.3	0.0	137.3	7		
59	SATPURA TPS	S	0.67	7.2	11.79	11.8	38.5	0.0	38.5	3		Non Payment of Dues
60	SEIONI TPP	P	0.64	2.8	5.06	5.1	133.3	0.0	133.3	26		
61	SHREE SINGAJI TPP	S	0.71	24.2	23.50	24.2	159.6	0.0	159.6	7		Materialization against the ACQ is more than trigger level
62	VINDHYACHAL STPS	C	0.69	55.5	43.60	55.5	922.3	0.0	922.3	17		
Maharashtra												
63	AMRAVATI TPS	P	0.62	19.0	11.07	19.0	78.4	0.0	78.4	4		Non Payment of Dues
64	BHUSAWAL TPS	S	0.72	16.9	11.44	16.9	145.8	0.0	145.8	9		
65	BUTIBORI TPP	P	0.67	0.0	5.31	5.3	59.7	0.0	59.7	11		
66	CHANDRAPUR(MAHARASHTRA) STPS	S	0.78	39.0	30.17	39.0	81.3	0.0	81.3	2		Non payment of dues
67	DAHANU TPS	P	0.62	5.5	4.09	5.5	4.8	0.0	4.8	1		Materialization against the ACQ is more than trigger level
68	DHARIWAL TPP	P	0.67	8.0	5.34	8.0	31.0	0.0	31.0	4		Materialization against the ACQ is more than trigger level
69	GMR WARORA TPS	P	0.67	7.6	5.29	7.6	0.5	0.0	0.5	0		Materialization against the ACQ is more than trigger level
70	KHAPARKHEDA TPS	S	0.89	7.7	15.72	15.7	193.7	0.0	193.7	12		
71	KORADI TPS	S	0.76	27.8	22.08	27.8	210.8	0.0	210.8	8		
72	MAUDA TPS	C	0.70	13.4	21.29	21.3	696.0	0.2	696.1	33		
73	NASIK TPS	S	0.81	5.6	6.72	6.7	21.2	0.0	21.2	3		Non payment of dues
74	PARAS TPS	S	0.74	7.1	4.90	7.1	29.8	0.0	29.8	4		Non payment of dues
75	PARLI TPS	S	0.67	7.5	6.65	7.5	44.2	0.0	44.2	6		Non payment of dues
76	SOLAPUR STPS	C	0.56	14.3	9.73	14.3	85.5	17.2	102.7	7		
77	TIRORA TPS	P	0.66	41.7	28.73	41.7	257.5	0.0	257.5	6		
78	WARDHA WARORA TPP	P	0.66	5.2	4.71	5.2	76.7	0.0	76.7	15		
Total of Western Region											0	
Southern												
Andhra Pradesh												
79	DAMODARAM SANJEEVAIAH TPS	S	0.66	12.8	13.85	13.8	57.0	0.0	57.0	4		Materialization against the ACQ is more than trigger level
80	Dr. N.TATA RAO TPS	S	0.77	19.0	17.90	19.0	147.2	0.0	147.2	8		Materialization against the ACQ is more than trigger level
81	PAINAMPURAM TPP	P	0.59	16.0	10.21	16.0	39.1	28.9	68.0	4		Materialization against the ACQ is more than trigger level
82	RAYALASEEMA TPS	S	0.76	18.8	16.60	18.8	47.4	0.0	47.4	3		Materialization against the ACQ is more than trigger level

COAL INDIA LIMITED
MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

Region/State	Name of Thermal Power Station		Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Actual Stock			In Days	Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock
							In '000 Tonnes'					
							Indigenous	Import	Total			
A	B		C	D	E	F	G	H	I	J=(I/F)		
122	BAKRESWAR TPS	S	0.62	14.1	8.61	14.1	79.8	0.0	79.8	6		
123	BANDEL TPS	S	0.78	3.9	3.39	3.9	11.3	0.0	11.3	3	Materialization against the ACQ is more than trigger level	
124	BUDGE BUDGE TPS	P	0.58	5.0	5.77	5.8	124.5	0.0	124.5	22		
125	D.P.L. TPS	S	0.68	6.6	4.90	6.6	11.0	0.0	11.0	2	Materialization against the ACQ is more than trigger level	
126	DURGAPUR STEEL TPS	C	0.69	14.3	9.16	14.3	40.6	0.0	40.6	3	Materialization against the ACQ is more than trigger level	
127	DURGAPUR TPS	C	1.06	0.0	2.93	2.9	58.2	0.0	58.2	20		
128	FARAKKA STPS	C	0.70	25.2	19.34	25.2	48.9	0.0	48.9	2	Materialization against the ACQ is more than trigger level	
129	HALDIA TPP	P	0.67	7.6	5.29	7.6	22.9	0.0	22.9	3	Materialization against the ACQ is more than trigger level	
130	HIRANMAYE TPP	P	0.72	5.2	2.83	5.2	35.5	0.0	35.5	7		
131	KOLAGHAT TPS	S	0.75	9.6	12.49	12.5	12.4	0.0	12.4	1	Materialization against the ACQ is more than trigger level	
132	MEJIA TPS	C	0.68	27.7	21.12	27.7	166.8	0.0	166.8	6	Materialization against the ACQ is more than trigger level	
133	RAGHUNATHPUR TPP	C	0.64	12.5	10.16	12.5	93.3	0.0	93.3	7		
134	SAGARDIGHI TPS	S	0.61	24.1	12.93	24.1	59.6	0.0	59.6	2	Materialization against the ACQ is more than trigger level	
135	SANTALDIH TPS	S	0.70	8.5	4.64	8.5	49.0	0.0	49.0	6		
136	SOUTHERN REPL. TPS	P	0.75	0.3	1.34	1.3	9.4	0.0	9.4	7	Plant diverting coal to the other plants	
Total of Eastern Region											0	
North Eastern												
Assam												
137	BONGAIGAON TPP	C	0.58	7.4	5.79	7.4	87.6	0.0	87.6	12		
Total of North Eastern Region											0	
Total Coal Stock			0.69	1733.4	1507.89	1878.5	20292.9	408.4	20701.2	11	0	

Note

1. https://cea.nic.in/wp-content/uploads/2020/04/guidelines_dcr.pdf	←	Link for New Methodology dated 08.11.2017
2. % Materialization against ACQ is taken from 01.04.21 to 07.12.2021		
3. Plant wise Specific Coal Consumption = (Coal Requirement @85% PLF*1000)/(Capacity*24*0.85)- Source:- Daily coal stock report, CEA		
4. List of Linked Plants with CIL taken from the Daily Coal Report of CEA showing status as on 13.12.2021		